

Wyniki obliczeń w punktach

Etap budowy

Receptor	X	Y	Z	LAeqD	
	m	m	m	dB(A)	
P1 (1,5m) _ PV2 160MW	828894,77	371517,22	179,86	36,6	
P1 (4,0m) _ PV2 160MW	828894,77	371517,22	182,36	36,7	
P2 (1,5m) _ PV2 160MW	828890,51	371772,18	179,44	39,9	
P2 (4,0m) _ PV2 160MW	828890,51	371772,18	181,94	40,0	
P3 (1,5m) _ PV2 160MW	828840,45	371929,31	180,90	39,8	
P3 (4,0m) _ PV2 160MW	828840,45	371929,31	183,40	39,9	
P4 (1,5m) _ PV2 160MW	829097,17	372201,11	183,69	42,6	
P4 (4,0m) _ PV2 160MW	829097,17	372201,11	186,19	42,7	
P5 (1,5m) _ PV2 160MW	829372,64	372287,48	179,55	43,8	
P5 (4,0m) _ PV2 160MW	829372,64	372287,48	182,05	43,9	
P6 (1,5m) _ PV2 160MW	829470,32	372395,59	181,69	46,8	
P6 (4,0m) _ PV2 160MW	829470,32	372395,59	184,19	47,0	
P7 (1,5m) _ PV2 160MW	829625,01	372871,78	179,54	36,6	
P7 (4,0m) _ PV2 160MW	829625,01	372871,78	182,04	36,6	
P8 (1,5m) _ PV2 160MW	829857,43	372988,13	178,13	34,2	
P8 (4,0m) _ PV2 160MW	829857,43	372988,13	180,63	34,2	
P9 (1,5m) _ PV2 160MW	830140,63	372802,90	179,24	34,2	
P9 (4,0m) _ PV2 160MW	830140,63	372802,90	181,74	34,2	
P10 (1,5m) _ PV2 160MW	830224,77	372387,71	179,90	35,7	
P10 (4,0m) _ PV2 160MW	830224,77	372387,71	182,40	35,8	
P11 (1,5m) _ PV2 160MW	830622,08	372551,01	180,57	30,6	
P11 (4,0m) _ PV2 160MW	830622,08	372551,01	183,07	30,6	
P12 (1,5m) _ PV2 160MW	830787,00	372504,54	180,50	29,2	
P12 (4,0m) _ PV2 160MW	830787,00	372504,54	183,00	29,2	
P13 (1,5m) _ PV2 160MW	831150,25	372714,79	180,76	26,1	
P13 (4,0m) _ PV2 160MW	831150,25	372714,79	183,26	26,1	
P14 (1,5m) _ PV2 160MW	831167,35	372893,10	181,07	25,5	
P14 (4,0m) _ PV2 160MW	831167,35	372893,10	183,57	25,6	
P15 (1,5m) _ PV2 160MW	831627,57	373261,69	180,09	22,0	
P15 (4,0m) _ PV2 160MW	831627,57	373261,69	182,59	22,0	
P16 (1,5m) _ PV2 160MW	831242,58	371781,84	180,32	25,5	
P16 (4,0m) _ PV2 160MW	831242,58	371781,84	182,82	25,5	
P17 (1,5m) _ PV2 160MW	832158,55	370749,86	182,20	18,6	
P17 (4,0m) _ PV2 160MW	832158,55	370749,86	184,70	18,7	
P18 (1,5m) _ PV2 160MW	831201,11	370682,12	182,67	22,6	
P18 (4,0m) _ PV2 160MW	831201,11	370682,12	185,17	22,6	
P19 (1,5m) _ PV2 160MW	830748,74	371130,38	182,66	26,6	
P19 (4,0m) _ PV2 160MW	830748,74	371130,38	185,16	26,6	
P20 (1,5m) _ PV2 160MW	830477,07	371442,19	180,92	29,7	
P20 (4,0m) _ PV2 160MW	830477,07	371442,19	183,42	29,7	
P21 (1,5m) _ PV2 160MW	830419,13	371181,60	182,69	28,7	

Wyniki obliczeń w punktach

Etap budowy

Receptor	X	Y	Z	LAeqD	
	m	m	m	dB(A)	
P21 (4,0m) _ PV2 160MW	830419,13	371181,60	185,19	28,7	
P22 (1,5m) _ PV2 160MW	830457,16	371034,83	181,93	27,6	
P22 (4,0m) _ PV2 160MW	830457,16	371034,83	184,43	27,7	
P23 (1,5m) _ PV2 160MW	830052,98	371008,47	182,41	29,4	
P23 (4,0m) _ PV2 160MW	830052,98	371008,47	184,91	29,5	
P24 (1,5m) _ PV2 160MW	829772,02	371243,87	180,16	33,7	
P24 (4,0m) _ PV2 160MW	829772,02	371243,87	182,66	33,8	
P25 (1,5m) _ PV2 160MW	829584,69	371235,19	183,19	33,5	
P25 (4,0m) _ PV2 160MW	829584,69	371235,19	185,69	33,5	
P26 (1,5m) _ PV2 160MW	829468,98	371128,37	182,95	32,7	
P26 (4,0m) _ PV2 160MW	829468,98	371128,37	185,45	32,7	
P27 (1,5m) _ PV2 160MW	829247,04	371103,15	182,64	32,6	
P27 (4,0m) _ PV2 160MW	829247,04	371103,15	185,14	32,6	
P28 (1,5m) _ PV2 160MW	828862,64	371423,56	179,11	35,1	
P28 (4,0m) _ PV2 160MW	828862,64	371423,56	181,61	35,2	